



Product Service

CERTIFICATE

No. Z2 104991 0004 Rev. 00

Holder of Certificate: **Q-SUN Anhui Co., Ltd.**
West of Jingliu Road, North of Weisan Road
239300 Tianchang City, Anhui Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062115003-00

Valid until: 2027-05-31

Date, 2022-06-02

(Zhulin Zhang)

CERTIFICATE

No. Z2 104991 0004 Rev. 00

Model(s):

QN-xxxHF, xxx = 630 to 660 in steps of 5
QN-xxxHF, xxx = 580 to 600 in steps of 5
xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

**Tested
according to:**

IEC 61215-1:2016
EN 61215-1:2016
IEC 61215-1-1:2016
EN 61215-1-1:2016
IEC 61215-2:2016
EN 61215-2:2017
IEC 61730-1:2016
EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
IEC 61730-2:2016
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06