



Product Service

# Attestation of Conformity

No. N8A 104991 0008 Rev. 00

**Holder of Attestation:** **Q-SUN Anhui Co., Ltd.**  
West of Jingliu Road, North of Weisan Road  
239300 Tianchang City, Anhui Province  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704062316712-00

**Date,** 2024-04-16

( Zhulin Zhang )

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

# Attestation of Conformity

No. N8A 104991 0008 Rev. 00

## Model(s):

QN-xxxHT-01, xxx = 670 to 710 in steps of 5  
 QN-xxxHT-01, xxx = 610 to 645 in steps of 5  
 QN-xxxHT-02, xxx = 585 to 620 in steps of 5  
 QN-xxxHT-02, xxx = 535 to 565 in steps of 5  
 QN-xxxHT-02, xxx = 480 to 505 in steps of 5  
 QN-xxxHT-02, xxx = 425 to 450 in steps of 5  
 QN-xxxHT-03, xxx = 605 to 640 in steps of 5  
 QN-xxxHT-03, xxx = 555 to 585 in steps of 5  
 QN-xxxHT-03, xxx = 505 to 530 in steps of 5  
 QN-xxxHT-03, xxx = 455 to 480 in steps of 5  
 QN-xxxHT-04, xxx = 585 to 615 in steps of 5  
 QN-xxxHT-04, xxx = 535 to 560 in steps of 5  
 QN-xxxHT-04, xxx = 440 to 460 in steps of 5  
 QN-xxxHT-05, xxx = 565 to 600 in steps of 5  
 QN-xxxHT-05, xxx = 520 to 550 in steps of 5  
 QN-xxxHT-05, xxx = 470 to 500 in steps of 5  
 QN-xxxHT-05, xxx = 425 to 450 in steps of 5  
 QN-xxxHT-06, xxx = 600 to 635 in steps of 5  
 QN-xxxHT-06, xxx = 555 to 585 in steps of 5  
 QN-xxxHT-06, xxx = 510 to 535 in steps of 5  
 QN-xxxHT-06, xxx = 465 to 485 in steps of 5  
 QN-xxxHT-06, xxx = 415 to 440 in steps of 5  
 QN-xxxHT-06, xxx = 370 to 390 in steps of 5  
 xxx is standing for rated output power at STC

## Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

## Tested according to:

EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.